



**NOTES:**

1. SERVICE CONNECTION SHALL BE PERPENDICULAR TO MAIN.
2. ADD DETECTOR TAPE TO ALL PIPE.
3. USE CLASS 50 DUCTILE IRON FOR SERVICES WITH LESS THAN 3' OF COVER.
4. NO SPLICES ON TRACER WIRE. MECHANICAL CONNECTORS ONLY IN CLEANOUTS.
5. EMBED PIPE IN #57 STONE FROM 6" BELOW INVERT TO 2" ABOVE CROWN.

<p>APPROVAL</p> <p><i>Paul W. Muffett</i></p> <p>EU MANAGER OF ENGINEERING</p> <p>JAN 15, 19</p> <p>DATE</p> <p>ISSUED: MAY 1, 1986</p>	<p>REVISED</p> <p>MAR 1, 94</p> <p>AUG 1, 94</p> <p>MAR 9, 95</p> <p>SEP 1, 98</p> <p>SEP 1, 09</p> <p>JAN 15, 19</p>	<p>EASTON UTILITIES STANDARD DETAILS</p> <p>DROP SEWER HOUSE CONNECTION</p> <p>STANDARD NO. SS-8.01</p>
-----------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------