


FRAME AND COVER REQUIRED	
PIPE SIZE	CASTING NUMBER
4"	EAST JORDAN IRON WORKS NO. 1570
6"	EAST JORDAN IRON WORKS NO. 1566

NOTES:

1. SERVICE CONNECTION SHALL BE PERPENDICULAR TO MAIN.
2. ADD DETECTOR TAPE TO ALL PIPE.
3. USE CLASS 50 DUCTILE IRON FOR SERVICES WITH LESS THAN 3' OF COVER.
4. NO SPLICES ON TRACER WIRE. MECHANICAL CONNECTORS ONLY IN CLEANOUTS.
5. EMBED PIPE IN #57 STONE FROM 6" BELOW INVERT TO 2" ABOVE CROWN.

APPROVAL  EU MANAGER OF ENGINEERING JAN 15, 19 DATE ISSUED: JAN 15, 2019	REVISED 	EASTON UTILITIES STANDARD DETAILS GRAVITY SEWER CLEANOUTS STANDARD NO. SS-8.03
--	-----------------------------	---