


- NOTES:
1. SEE CLEANOUT DETAIL SS-8.03 FOR SPECIFICS ON ITS INSTALLATION.
 2. TRACER WIRE TO BE 10 GAUGE, GREEN COATED, SOLID COPPER WIRE.
 3. TRACER WIRE TO BE TAPED TO SERVICE LINE IMMEDIATELY ADJACENT TO FOUNDATION.
 4. PLACE CLEANOUT IMMEDIATELY ADJACENT TO HOUSE, 3' TO 5' FROM FOUNDATION.
 5. SECOND CLEANOUT AT PROPERTY LINE.
 6. NO SPLICES ON TRACER WIRE; TAPED MECHANICAL CONNECTORS ONLY INSIDE CLEANOUT FRAME AND COVER.
 7. PROVIDE 12" OF SLACK WIRE INSIDE OF CLEANOUT FRAME AND COVER.

APPROVAL	REVISED	EASTON UTILITIES STANDARD DETAILS SEWER SERVICE TRACER WIRE STANDARD NO. SS-8.04
 EU MANAGER OF ENGINEERING		
<u>JAN 15, 19</u> DATE		
ISSUED: <u>JAN 15, 2019</u>		