



Notes:

1. 10 Gauge Solid Copper Tracer Wire; Blue Jacket.
2. Thoroughly Tape Mechanical Connections With Electrical Tape.
3. Installation Of Water Service Into Foundation Per Town Of Easton Standards.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS WATER SERVICE CONNECTION
 EU MANAGER OF ENGINEERING DATE	JUN 23, 97	
	MAR 1, 98	
	MAR 1, 07	
	SEP 1, 09	
	SEP 15, 14	
ISSUED: <u>JUNE 5, 1997</u>	AUG 6, 19	STANDARD NO. W-7.04