



Note: 1" Body Size Shown.

| BODY SIZE | 3/4" | 1" | 1-1/4" | 1-1/2" | 2" |
|---------------|--------|---------|--------|---------|---------|
| A | 11-1/8 | 13-1/4 | 16-3/8 | 16-3/4 | 19-1/2 |
| B | 4 | 5-1/8 | 5 | 4-7/8 | 6-1/4 |
| C | 3-1/8 | 4 | 3-5/16 | 3-1/2 | 4 |
| D | 6-3/16 | 7-1/2 | 9-1/2 | 9-3/4 | 13-3/8 |
| E | 2-1/8 | 1-11/16 | 3 | 3-1/8 | 3-7/16 |
| F | 15/16 | 1-11/16 | 2 | 2-11/16 | 2-11/16 |
| NET WT. (lbs) | 5 | 12 | 15 | 15.9 | 25.7 |

Notes:

1. Reduced Pressure Backflow Preventer Shall Be Equivalent To WATTS Water Technologies, Series LF007 Or Equal As Approved By Easton Utilities.
2. Assembly To Be Used For Pipe 3/4" To 2".
3. To Be Installed In Horizontal Position With Easy Access For Testing.

| | | |
|--------------------------------|---------|---|
| APPROVAL | REVISED | <p>TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS BACKFLOW PREVENTER DOUBLE CHECK VALVE ASSEMBLY</p> |
| <i>[Signature]</i> | | |
| EU MANAGER OF ENGINEERING DATE | | |
| | | |
| | | |
| ISSUED: APRIL 1, 2016 | | STANDARD NO. W-5.20 |