

SET TOP OF LID FLUSH WITH GRADE

6" DUCT,
4" DUCT
OR 2 1/2" DUCT

1"
(TYP.)

WIRE MESH BETWEEN BOX AND STONE BOX OPENING APPROX. 19"x31"

6" TO BASE LAYER OF 3/4" WASHED STONE

SIDE VIEW NOT TO SCALE

COMPACT SUBGRADE TO 95% MODIFIED PROCTOR AT 2% OPTIMUM MOISTURE CONTENT PER ASTM D1557.



CORE DRILL INTO BOX

END VIEW NOT TO SCALE

NOTES:

1. SEE CONDUIT AND DUCT BANK NOTES ON E-100.1.2 STANDARD DETAILS.
2. LID SHALL BE MARKED ELECTRIC OR CATV AS APPROPRIATE FOR THE PROJECT.

V:\Dwgs\Standard Details 2024\E-105.1.dwg Mar 12, 2025 - 10:16am, (ldennis)

 Life. Made better.™	APPROVAL  EU ENGINEERING DEPARTMENT 3/17/2025 DATE	REVISED 3/12/2025	EASTON UTILITIES STANDARD DETAILS 36" x 36" x 30" QUAZITE BOX
	ISSUED: JANUARY 2024		