



**NOTES:**

1. STREETLIGHT LOCATION, POLE SPACING, ARM LENGTH, LUMINAIRE HEIGHT AND TYPE TO BE DETERMINED BY PHOTOMETRIC DESIGN. CONTACT EASTON UTILITIES.
2. STREETLIGHT POLE AND LUMINAIRE PART NUMBERS CHANGE BASED ON THE TOWN OF EASTON'S STANDARD. CONTACT EASTON UTILITIES TO COORDINATE THE PURCHASE OF ANY STREETLIGHT EQUIPMENT TO BE ASSURED ITS ACCEPTANCE.
3. INSTALL STREETLIGHT TO MANUFACTURES SPECIFICATIONS.
4. UNDERGROUND DUCT
  - A. UNDERGROUND DUCT TO BE 1 1/4" SCHEDULE 40 PVC WITH DETECTABLE PULL TAPE FROM STREETLIGHT TO STREETLIGHT OR TRANSFORMER.
  - B. DUCT TO HAVE A MINIMUM OF 24" OF COVER. ALL DUCT TO BE INSPECTED BY EASTON UTILITIES BEFORE BACKFILLING.
  - C. 1 1/4" CONDUIT SHALL BE INSTALLED IN POURED FOOTER 24" BELOW FINISHED GRADE.
  - D. UNDERGROUND DUCT SHALL BE STUBBED UP INSIDE POLE APPROXIMATELY 1" FROM HANDHOLE DOOR.



Life. Made better.™

**APPROVAL**

*[Signature]*  
 EU ENGINEERING DEPARTMENT

*12/4/2024*  
 DATE

**REVISED**

**EASTON UTILITIES  
 STANDARD DETAILS**

**ALUMINUM POLE  
 STREETLIGHT  
 INSTALLATION**

**ISSUED: DEC 2024**

**STANDARD NO.: E-106.1.2**