



CONDUIT REQUIREMENTS

SERVICE SIZE	CONDUIT SIZE	QUANTITY
400A	4"	1
600A	4"	2
800A	4"	2
1200A	4"	3
1600A	4"	4
2000A	4"	6

- NOTES**
1. SEE STANDARD DETAIL E-100.1.2 FOR CONDUIT SPECIFICATIONS.
 2. METERING AND EQUIPMENT SHALL BE INSTALLED ON EXTERIOR OF BUILDING.
 3. EACH METER MUST HAVE A PERMANANT FIXED LABEL DESIGNATING 911 ADDRESS AND APARTMENT NUMBER BEFORE METER CAN BE INSTALLED.
 4. METER SOCKETS MUST BE RINGLESS.
 5. METER SHALL NOT BE OBSTRUCTED AND A TEN FOOT CLEARANCE MUST BE MAINTAINED FOR SAFETY.



 Life. Made better.™	APPROVAL	REVISED	EASTON UTILITIES STANDARD DETAILS	
	 EU ENGINEERING DEPARTMENT	APRIL 2026		METER STACK DETAIL
	4/14/2026 DATE			
	ISSUED: MAY 2025		STANDARD NO.: E-107.3	