



NOTES

1. SEE STANDARD DETAIL E-100.1.2 FOR CONDUIT SPECIFICATIONS.
2. SEE STANDARD DETAIL E-103.2 FOR METER CABINET BASE.
3. METER SHALL NOT BE OBSTRUCTED AND A SIX FOOT CLEARANCE MUST BE MAINTAINED FOR SAFETY.
4. COORDINATE CONDUIT SIZES FOR PROJECT WITH EASTON UTILITIES.



APPROVAL

[Signature]

EU ENGINEERING DEPARTMENT

4/14/2026

DATE

REVISED

**EASTON UTILITIES
STANDARD DETAILS**

**PRIMARY METER
DETAIL**

ISSUED: APRIL 2026

STANDARD NO.: E-107.4