



**NOTES:**

1. SERVICE CONNECTION SHALL BE PERPENDICULAR TO MAIN.
2. ADD DETECTOR TAPE TO ALL PIPE.
3. USE CLASS 50 DUCTILE IRON FOR SERVICES WITH LESS THAN 3' OF COVER.
4. NO SPLICES ON TRACER WIRE. MECHANICAL CONNECTORS ONLY IN CLEANOUTS.
5. EMBED PIPE IN #57 STONE FROM 6" BELOW INVERT TO 2" ABOVE CROWN.
6. INSTALLATION OF SEWER LATERAL INTO FOUNDATION PER TOWN OF EASTON BUILDING AND PLUMBING CODE.
7. PROVIDE VIDEO INSPECTION OF LATERAL FROM CLEANOUT AT HOUSE/STRUCTURE, TO MAIN.



Life. Made better.™

	APPROVAL	REVISED	
	 EU ENGINEERING DEPARTMENT 1/31/2024 DATE		<b>EASTON UTILITIES STANDARD DETAILS</b>  <b>SEWER HOUSE CONNECTION</b>
	<b>ISSUED: JANUARY 2024</b>		<b>STANDARD NO.: SS-102.2</b>