



NOTES:

1. SERVICE CONNECTION SHALL BE PERPENDICULAR TO MAIN.
2. WARNING TAPE SHALL BE 12" ABOVE PIPE AND 12" BELOW GROUND SURFACE.
3. USE CLASS 50 DUCTILE IRON FOR SERVICES WITH LESS THAN 3' OF COVER.
4. NO SPLICES ON TRACER WIRE. MECHANICAL CONNECTORS ONLY IN CLEANOUTS.
5. EMBED PIPE IN #57 STONE FROM 6" BELOW INVERT TO 2" ABOVE CROWN.

O:\standets\REVISED 2024\REVISED-RENUMBERED 2024\SS-102.3.dwg, 1/31/2024 9:04:51 AM, 1:1



Life. Made better.™

APPROVAL	REVISED	EASTON UTILITIES STANDARD DETAILS DROP SEWER HOUSE CONNECTION
 EU ENGINEERING DEPARTMENT		
1/31/2024 DATE		
ISSUED: JANUARY 2024		STANDARD NO.: SS-102.3