

## NOTES:

- 1. USE SELECT GRANULAR BACKFILL ONLY.
- 2. PROVIDE AS MUCH SEPARATION AS PERMITTED BY TRENCH WIDTH.
- TRENCH TAPE (WARNING TAPE) SHALL BE PLACED 12" ABOVE PIPE AND 12" ABOVE BELOW GROUND SURFACE.
- 4. GAS MAIN CONSTRUCTION BY EASTON UTILITIES IN ACCORDANCE WITH EASTON UTILITIES GAS CONSTRUCTION STANDARDS.
- REINFORCED COATED TRACER WIRE AS MANUFACTURED BY COPPERHEAD INDUSTRIES, LLC, OR AN APPROVED EQUAL.
- 6. THOROUGHLY TAPE MECHANICAL CONNECTIONS OF TRACER WIRE WITH ELECTRICAL TAPE.

	APPROVAL	REVISED	
SON DAY	EU ENGINEERING DEPARTMENT		EASTON UTILITIES STANDARD DETAILS
Life. Made better."	1/31/2024 DATE		WATER MAIN JOINT TRENCHING
	ISSUED: JANUARY 2024		STANDARD NO.: W-100.2