



O:\standets\REVISED 2024\REVISED-RENUMBERED 2024\W-101.2.1.dwg, 1/30/2024 12:55:35 PM, 1:1

DIMENSION TABLE							
PIPE DIA. IN.	TABLE PRESSURE PSI	BEND ANGLE (DEG.)	CONCRETE VOLUME (CY)	CUBE SIZE (FT.)	STIRRUP DIA. (IN.)	STIRRUP EMBEDMENT (IN.)	STIRRUP BAR #
4"	250	11.25	0.21	1.8	5/8	17	5
		22.5	0.43	2.3			
		45	0.77	2.8			
6"	250	11.25	0.48	2.4	5/8	17	5
		22.5	0.95	3.0			
		45	1.79	3.6			
8"	250	11.25	0.86	2.9	5/8	17	5
		22.5	1.65	3.5			
		45	3.22	4.4			
10"	250	11.25	1.39	3.3	5/8	17	5
		22.5	2.62	4.1			
		45	4.97	4.1			
12"	250	11.25	1.94	3.7	5/8	17	5
		22.5	3.91	4.7			
		45	6.89	5.7	7/8	24	7
14"	250	11.25	2.62	4.1	5/8	17	5
		22.5	5.26	5.2	3/4	20	6
		45	9.70	6.4	1	27	8
16"	250	11.25	3.44	4.5	5/8	17	5
		22.5	6.89	5.7	7/8	24	7
		45	12.63	7.0	1 1/8	30	9

 <p>Life. Made better.™</p>	APPROVAL  EU ENGINEERING DEPARTMENT 1/31/2024 DATE	REVISED 	EASTON UTILITIES STANDARD DETAILS THRUST BLOCK VERTICAL BEND DIMENSION TABLE STANDARD NO.: W-101.2.1
	ISSUED: JANUARY 2024		